



NISHVIKA TESTING LABORATORIES LLP

NISHVIKA

01, Vishnu Kuteera, C.M. Layout, Maruthinagar, Chikkabanavara, Bengaluru-560090.
Ph: 7483910234, 9880113452. Email: nishvikatestinglab@gmail.com



TEST REPORT

Format No.: NTL/ 7.8.2 /F/ 01

Name & Address of the Customer	BROAD VISION WORLD SCHOOL, No.80/9, Thanisandra Main road , Beside Bharath Petroleum , Bangalore .	Sample No: NTL/2025-2026/02/881
		Report No : NTL/2025-2026/02/BW/04
		ULR No: TC127222600000881F
		Product: water
		Sample type: Borewell water used for Drinking Purpose
Sample Collected On	21.02.2026	Date of Completion: 25.02.2026
Date of Sample Receipt	21.02.2026	Date of Report: 25.02.2026
Analysis start date	21.02.2026	Sample Condition: Good
Sampling Done by	Customer Representative	Env. Condition: Temp. 25°C & RH: 58%
Sample Received by	NTL Representative	Sampling Method: Not Applicable

Sl. No.	Test Name	Result	IS 10500:2012 Specifications		Test Method
			Acceptable Limit	Permissible Limit	
Chemical Tests					
1.	pH Value @25°C	7.32	6.5 – 8. 5	No relaxation	IS 3025 (Part-11)
2.	Color	BDL (<1.0)	5	15	IS 3025 (Part-04)
3.	Odor	Agreeable	Agreeable	Agreeable	IS 3025 (Part-05)
4.	Turbidity. NTU	(<1.0)	1	5	IS 3025 (Part-10)
5.	Total Dissolved Solids, mg/L	244	500	2000	IS 3025 (Part-16)
6.	Hardness as CaCO ₃ , mg/L	140	200	600	IS 3025 (Part-21)
7.	Calcium as Ca , mg/L	33.60	75	200	IS 3025 (Part-40)
8.	Magnesium as Mg , mg/L	13.60	30	100	IS 3025 (Part-46)
9.	Total alkalinity as CaCO ₃ , mg/L	140.0	200	600	IS 3025 (Part-23)
10.	Chlorides as Cl, mg/L	30.40	250	1000	IS 3025 (Part-32)
11.	Fluoride as F, mg/L	0.78	1.0	1.5	APHA 24th Edition 4500 F-B,D
12.	Iron as Fe, mg/L	BDL(<0.1)	0.3	No Relaxation	IS 3025 (Part-53)
13.	Sulphate as SO ₄ ,mg/L	5.60	200	400	IS 3025 (Part-24/Sec1)
14.	Boron as B, mg/L	BDL (<0.1)	0.5	1.0	IS 3025 (Part-57)
15.	Nitrate as NO ₃ , mg/L	BDL (<0.1)	45	No Relaxation	IS 3025 (Part-34)
16.	Conductivity @25°C,µs/cm	400	Not Specified	Not Specified	IS 3025 (Part-14)
17.	Total suspended solids, mg/L	BDL(<1.0)	Not Specified	Not Specified	IS 3025 (Part-17)

Statement of Conformity: The above tested parameters confirm as per IS 10500 limits for above tested parameters and the results are related to the parameters tested.

Note: BDL – Below Detection Level



Authorized Signatory

Pavithra
Pavithramma. T
Technical Manager

---End of Report---

TEST REPORT

Format No.: NTL/ 7.8.2 /F/ 01

Name & Address of the Customer	BROAD VISION WORLD SCHOOL, No.80/9, Thanisandra Main road , Beside Bharath Petroleum , Bangalore .	Sample Code : NTL/2025-2026 /02/881
		Product: water
Date of Sample Collection	21.02.2026	Sample type: Borewell water used for Drinking Purpose
Date of Sample Receipt:	21.02.2026	Date of Completion: 25.02.2026
Date of Analysis:	21.02.2026	Date of Report: 25.02.2026
Sample Drawn By:	Customer Representative	Report No.: NTL/2025 – 2026 /02 /BW/04
Sample Received By:	NTL Representative	Sample Condition: Satisfactory
Environmental Condition: Temperature: 25°C; Humidity: 58 % RH		Sampling Method: Not Applicable

Sl. No.	Test Name	Result	Specifications as per IS 10500:2012	Test Method
Bacteriological Tests				
1	Coliform, per 100ml	Absent	Shall not be detectable in any 100 ml sample	IS 15185
2	E. Coli, per 100ml	Absent	Shall not be detectable in any 100 ml sample	IS 15185

Statement of Conformity: The above tested parameters and the results are related to the parameters tested only.



Authorized Signatory

Pavithra
Pavithramma. T
Technical Manager

---End of Report---

Note:

1. The Results listed above pertain only to the tested and applicable parameters
2. Samples which are degradable will be disposed immediately after testing and others will be disposed after 30 days from the date of sample supplied unless otherwise specified
3. Total liability of our laboratory is limited to the invoice amount
4. This report is not to be reproduced either wholly or in part and cannot be used as evidence in the court of Law and should not be used in any advertising media without written approval of the laboratory
5. In case any reconfirmation of contents of this certification is required, please contact our office.
6. Subjected to Bangalore jurisdiction.